



## Annexure C

### PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated:

It is certified that an inspection team headed by Dr. Roustan Bagchi (2nd MO), Debani Basu (PHN)

(Name of Officers with designation) from Ajit K. Roy (BSI) Rajganj R.H. PHED

inspected the Himalayan International Residential School

(Name & Address of the school) on 17-01-2025 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. MRNO Pg No-30/Book No-20 dated 24-01-2025

of Jalpaiguri Divisional Laboratory (PHED Lab) certified that the

Himalayan International Residential School (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 23-01-2026

Signature with Seal: [Signature]

Name: Dr. RAHUL ROY

Designation: Block Medical Officer of Health & FW

Name & Address of the Office / Department: Rajganj /

To  
HIMALAYAN INTERNATIONAL RESIDENTIAL SCHOOL  
PO. RAJGANJ, DIST. JALPAIGURI, PIN - 735134, WB  
(Name & Address of the Institution)

Block Medical Officer of Health & FW  
Rajganj Rural Hospital  
Jalpaiguri

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



**GOVT. OF WEST BENGAL.**  
**OFFICE OF THE EXECUTIVE ENGINEER**  
**JALPAIGURI DIVISION, P.H.E DTE, JALPAIGURI**

**JALPAIGURI DIVISIONAL LABORATORY**  
**REPORT OF WATER QUALITY TEST (Chemical & Physical & Bacteriological)**

Date of Sample Receiving : 16/01/2025

Date of Sample Testing 16/01/2025

Ref. of Charges: GRN No.192024250359891871  
M.R. No. Pg No-30/Book No-20

SL. NO.	NAME OF LOCATION	TYPE OF WATER SOURCE	CHEMICAL & PHYSICAL PARAMETER					BACTERIOLOGICAL PARAMETER (CFU= Colony forming unit )	
			Iron (mg/L)	TDS (mg/L)	Total Hardness (mg/L)	Turbidity (NTU)	pH	T.C (CFU/ 100ml)	F.C (CFU/ 100ml)
1	HIMALAYAN INTERNATIONAL RESIDENTIAL SCHOOL, KALINAGAR, RAIGANI.	FILTER WATER	0.193	61	40	1.38	6.37	0	0
Permissible Limit for Drinking Water as per IS 10500:2012			1	2000	600	5	6.5-8.5	0	0

N.B: The test done with the sample as deposited by the Party.

Depositor name/ Client Name: PRINCIPAL, HIMALAYAN INTERNATIONAL RESIDENTIAL SCHOOL, KALINAGAR, RAIGANI.

CHEMIST  
DISTRICT WATER TESTING LAB  
P.H.E.Dte

BACTERIOLOGIST  
DISTRICT WATER TESTING LAB  
P.H.E.Dte

JUNIOR ENGINEER  
IN CHARGE OF LABORATORY  
P.H.E.Dte

ASSISTANT ENGINEER  
JALPAIGURI R.W.S SUB DIVISION,  
P.H.E.Dte

EXECUTIVE ENGINEER  
JALPAIGURI DIVISION  
P.H.E.Dte